



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----------------------------|-----|-----|------|------|-----|
| 1 | 8.7 | 38 | | | Y |
| 2 | 8.6 | 40 | | | Y |
| 3 | OFF | OFF | | | |
| 4 | OFF | OFF | | | |
| 5 | 8.2 | 40 | | | Y |
| 6 | 8.2 | 40 | | | Y |
| 7 | 8.5 | 42 | | | Y |
| 8 | OFF | OFF | | | |
| 9 | 8.4 | 40 | | | Y |
| 10 | 7.9 | 42 | | | Y |
| 11 | 7.5 | 38 | | | Y |
| 12 | OFF | OFF | | | |
| 13 | OFF | OFF | | | |
| 14 | 8.1 | 42 | | | Y |
| 15 | 7.5 | 38 | | | Y |
| 16 | 7.0 | 35 | | | N |
| 17 | 7.7 | 44 | | | Y |
| 18 | OFF | OFF | | | |
| 19 | 7.7 | 44 | | | Y |
| 20 | 7.6 | 52 | | | Y |
| 21 | 9.0 | 42 | | | Y |
| 22 | 9.0 | 42 | | | Y |
| 23 | OFF | OFF | | | |
| 24 | 8.8 | 50 | | | Y |
| 25 | 8.7 | 48 | | | Y |
| 26 | 7.8 | 50 | | | Y |
| 27 | OFF | OFF | | | |
| 28 | OFF | OFF | | | |
| 29 | 7.6 | 54 | | | Y |
| 30 | 7.5 | 52 | | | Y |
| (NO=N=Excursions) Total N's | | | | | 1 |

<< Have minimums been met for this day?

| | | | | | | | |
|--------------------|---------------|---|---|---|---|---|---|
| ENTRY POINT | | | | | | | |
| PWS ID: | 4 | 1 | 0 | 0 | 0 | 4 | 1 |
| System Name: | City of Amity | | | | | | |
| Entry Point: | EP-D | | | | | | |
| Sample Period: | Apr-21 | | | | | | |
| | Month / Year | | | | | | |

Number of excursions* during this month: 1
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

| | |
|--|------------------|
| Minimum Water Quality Parameters as set by State: | |
| pH | 7.5 |
| Alk | 30 (Alkalinity) |
| PO4 | (Orthophosphate) |
| Sili | (Silicate) |

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Tuesday, May 4, 2021