



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	OFF	OFF			
3	7.5	66			Y
4	8.4	44			Y
5	8.3	44			Y
6	OFF	OFF			
7	OFF	OFF			
8	8.5	42			Y
9	8.4	45			Y
10	8.9	44			Y
11	8.6	50			Y
12	8.1	48			Y
13	8.1	48			Y
14	7.8	46			Y
15	OFF	OFF			
16	7.9	46			Y
17	7.9	48			Y
18	7.7	46			Y
19	7.5	44			Y
20	OFF	OFF			
21	OFF	OFF			
22	7.6	48			Y
23	8.1	48			Y
24	7.9	40			Y
25	8.2	44			Y
26	7.8	42			Y
27	7.8	42			Y
28	7.8	40			Y
29	7.9	42			Y
30	OFF	OFF			
31	8.2	43			Y

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	May-21						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Thursday, June 3, 2021

(NO=N=Excursions) **Total N's**