



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	40			Y
2	7.5	58			Y
3	8.4	48			Y
4	8.1	46			Y
5	8.1	46			Y
6	8.0	48			Y
7	OFF	OFF			
8	8.3	48			Y
9	8.5	48			Y
10	8.5	40			Y
11	OFF	OFF			
12	OFF	OFF			
13	8.0	50			Y
14	7.5	40			Y
15	7.5	40			Y
16	7.5	34			Y
17	8.8	40			Y
18	8.6	42			Y
19	8.7	40			Y
20	8.6	40			Y
21	8.9	42			Y
22	8.9	44			Y
23	9.1	50			Y
24	OFF	OFF			
25	OFF	OFF			
26	8.8	45			Y
27	8.8	48			Y
28	8.4	50			Y
29	8.6	48			Y
30	8.0	52			Y
(NO=N=Excursions) Total N's					<b>0</b>

<< Have minimums been met for this day?

<b>ENTRY POINT</b>							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Jun-21						
	Month / Year						

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:** *Richard A. Howard Sr.*

**Date:** Wednesday, July 7, 2021