



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	7.9	42			Y
3	8.0	50			Y
4	7.9	50			Y
5	7.9	52			Y
6	OFF	OFF			
7	OFF	OFF			
8	8.1	46			Y
9	8.5	46			Y
10	8.1	48			Y
11	OFF	OFF			
12	OFF	OFF			
13	8.1	46			Y
14	8.5	50			Y
15	8.5	54			Y
16	8.4	52			Y
17	OFF	OFF			
18	8.4	54			Y
19	8.5	44			Y
20	8.0	48			Y
21	8.3	48			Y
22	OFF	OFF			
23	8.0	46			Y
24	8.1	54			Y
25	8.1	56			Y
26	OFF	OFF			
27	OFF	OFF			
28	8.3	50			Y
29	8.1	52			Y
30	8.2	50			Y
31	OFF	OFF			

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Jul-21						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Richard A. Howard Sr.
Signature: *Richard A. Howard Sr.*

Date: Tuesday, August 3, 2021

(NO=N=Excursions) **Total N's**