



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.3	56			Y
2	8.5	50			Y
3	8.6	50			Y
4	8.4	50			Y
5	OFF	OFF			
6	8.4	48			Y
7	8.4	50			Y
8	8.4	52			Y
9	8.1	60			Y
10	OFF	OFF			
11	7.9	52			Y
12	8.1	50			Y
13	8.3	56			Y
14	8.3	54			Y
15	OFF	OFF			
16	8.6	60			Y
17	8.4	62			Y
18	8.3	58			Y
19	OFF	OFF			
20	8.3	48			Y
21	8.3	48			Y
22	8.9	50			Y
23	7.8	42			Y
24	7.7	40			Y
25	OFF	OFF			
26	OFF	OFF			
27	8.0	58			Y
28	8.0	56			Y
29	OFF	OFF			
30	8.8	64			Y
31	8.0	54			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Aug-21
 Month / Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

7.5

 Alk

30

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Sili

--

 (Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Saturday, September 4, 2021

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381