



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	38			Y
2	OFF	OFF			
3	8.9	40			Y
4	OFF	OFF			
5	OFF	OFF			
6	8.4	40			Y
7	8.4	46			Y
8	OFF	OFF			
9	OFF	OFF			
10	8.5	42			Y
11	8.5	46			Y
12	OFF	OFF			
13	8.5	40			Y
14	8.5	58			Y
15	OFF	OFF			
16	8.2	48			Y
17	8.3	50			Y
18	8.4	50			Y
19	OFF	OFF			
20	8.7	48			Y
21	8.4	54			Y
22	8.4	44			Y
23	7.5	40			Y
24	OFF	OFF			
25	7.5	50			Y
26	7.6	54			Y
27	7.6	58			Y
28	8.4	54			Y
29	7.5	42			Y
30	OFF	OFF			
31	OFF	OFF			

<< Have minimums been met for this day?

<b>ENTRY POINT</b>							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Oct-21						
	Month / Year						

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

**Print Name:** Richard A. Howard Sr.  
**Signature:** *Richard A. Howard Sr.*

**Date:** Tuesday, November 2, 2021

(NO=N=Excursions) **Total N's**