



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	58			Y
2	8.2	46			Y
3	7.5	48			Y
4	8.8	36			Y
5	OFF	OFF			
6	7.6	42			Y
7	7.5	40			Y
8	OFF	OFF			
9	OFF	OFF			
10	7.8	45			Y
11	7.5	42			Y
12	OFF	OFF			
13	OFF	OFF			
14	7.9	50			Y
15	7.6	42			Y
16	OFF	OFF			
17	7.6	56			Y
18	7.5	35			Y
19	7.6	38			Y
20	OFF	OFF			
21	OFF	OFF			
22	8.0	36			Y
23	7.5	38			Y
24	7.7	56			Y
25	OFF	OFF			
26	OFF	OFF			
27	OFF	OFF			
28	7.6	50			Y
29	7.8	44			Y
30	7.8	50			Y

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Nov-21						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Richard A. Howard Sr.
Signature: *Richard A. Howard Sr.*

Date: Saturday, December 4, 2021

(NO=N=Excursions) **Total N's**