

### Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	OFF	OFF			
3	8.9	44			Y
4	7.7	42			Y
5	OFF	OFF			
6	OFF	OFF			
7	OFF	OFF			
8	8.8	54			Y
9	8.4	45			Y
10	OFF	OFF			
11	OFF	OFF			
12	OFF	OFF			
13	8.2	56			Y
14	7.2	58			N
15	OFF	OFF			
16	OFF	OFF			
17	OFF	OFF			
18	7.6	56			Y
19	7.5	48			Y
20	OFF	OFF			
21	OFF	OFF			
22	7.5	52			Y
23	7.5	54			Y
24	7.5	50			Y
25	OFF	OFF			
26	OFF	OFF			
27	7.5	54			Y
28	7.6	50			Y
29	7.6	50			Y
30	7.5	58			Y
31	OFF	OFF			
(NO=N=Excursions) Total N's					1

<< Have minimums been met for this day?

#### ENTRY POINT

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity  
 Entry Point: EP-D  
 Sample Period: Dec-21  
 Month / Year

Number of excursions\* during this month:

(Count the number of days when any WQP was less then the minimum required)



Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Richardd A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Thursday, January 7, 2021

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381