



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	7.6	56			Y
3	8.8	56			Y
4	8.5	50			Y
5	8.0	56			Y
6	8.1	54			Y
7	7.7	62			Y
8	OFF	OFF			
9	7.5	60			Y
10	8.4	55			Y
11	7.5	56			Y
12	7.2	50			N
13	OFF	OFF			
14	7.4	50			N
15	7.6	40			Y
16	7.5	50			Y
17	7.4	50			N
18	OFF	OFF			
19	7.6	50			Y
20	7.8	44			Y
21	7.9	50			Y
22	7.8	50			Y
23	OFF	OFF			
24	7.6	54			Y
25	7.6	52			Y
26	7.5	50			Y
27	7.6	52			Y
28	7.5	45			Y
29	OFF	OFF			
30	OFF	OFF			
31	7.5	44			Y

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	<u>City of Amity</u>						
Entry Point:	<u>EP-D</u>						
Sample Period:	<u>Jan-22</u>						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:		
pH	<input type="text" value="7.5"/>	
Alk	<input type="text" value="30"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Monday, February 7, 2022

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381