



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	52			Y
2	7.5	50			Y
3	8.6	54			Y
4	7.6	45			Y
5	OFF	OFF			
6	OFF	OFF			
7	7.8	48			Y
8	7.5	68			Y
9	7.7	42			Y
10	OFF	OFF			
11	OFF	OFF			
12	8.8	46			Y
13	8.7	48			Y
14	7.6	68			Y
15	OFF	OFF			
16	OFF	OFF			
17	8.4	50			Y
18	7.6	60			Y
19	7.5	70			Y
20	OFF	OFF			
21	OFF	OFF			
22	OFF	OFF			
23	7.9	58			Y
24	8.0	50			Y
25	OFF	OFF			
26	OFF	OFF			
27	8.4	54			Y
28	8.3	56			Y
(NO=N=Excursions) Total N's					<b>0</b>

<< Have minimums been met for this day?

<b>ENTRY POINT</b>							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Feb-22						
	Month / Year						

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:** *Richard A. Howard Sr.*

**Date:** Monday, March 7, 2022

Send to DHS within 10 days after end of sampling period  
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381