



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	7.6	68			Y
3	7.5	66			Y
4	OFF	OFF			
5	OFF	OFF			
6	OFF	OFF			
7	7.5	60			Y
8	7.5	52			Y
9	OFF	OFF			
10	OFF	OFF			
11	OFF	OFF			
12	7.5	58			Y
13	7.6	60			Y
14	OFF	OFF			
15	OFF	OFF			
16	7.5	68			Y
17	OFF	OFF			
18	OFF	OFF			
19	OFF	OFF			
20	7.7	60			Y
21	7.5	58			Y
22	OFF	OFF			
23	OFF	OFF			
24	7.5	66			Y
25	7.5	62			Y
26	7.5	56			Y
27	OFF	OFF			
28	OFF	OFF			
29	7.6	58			Y
30	7.6	58			Y
(NO=N=Excursions) Total N's					0

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	<u>City of Amity</u>						
Entry Point:	<u>EP-D</u>						
Sample Period:	<u>Apr-22</u>						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Richard A Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Thursday, May 5, 2022

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381