



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	OFF	OFF			
3	OFF	OFF			
4	7.5	68			Y
5	7.6	66			Y
6	OFF	OFF			
7	OFF	OFF			
8	OFF	OFF			
9	8.0	54			Y
10	7.9	60			Y
11	OFF	OFF			
12	OFF	OFF			
13	8.4	60			Y
14	7.6	54			Y
15	7.5	64			Y
16	OFF	OFF			
17	OFF	OFF			
18	OFF	OFF			
19	7.6	66			Y
20	7.6	55			Y
21	OFF	OFF			
22	OFF	OFF			
23	OFF	OFF			
24	8.5	56			Y
25	7.9	62			Y
26	OFF	OFF			
27	OFF	OFF			
28	OFF	OFF			
29	OFF	OFF			
30	7.9	56			Y
31	7.7	74			Y

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	<u>City of Amity</u>						
Entry Point:	<u>EP-D</u>						
Sample Period:	<u>May-22</u>						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Saturday, May 7, 2022

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381