



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	70			Y
2	7.8	82			Y
3	8.3	44			Y
4	OFF	OFF			
5	OFF	OFF			
6	OFF	OFF			
7	8.5	58			Y
8	8.7	52			Y
9	8.7	52			Y
10	8.7	50			Y
11	8.7	50			Y
12	8.4	52			Y
13	OFF	OFF			
14	OFF	OFF			
15	8.7	48			Y
16	8.6	40			Y
17	8.6	42			Y
18	OFF	OFF			
19	OFF	OFF			
20	8.5	42			Y
21	8.9	44			Y
22	8.4	40			Y
23	OFF	OFF			
24	OFF	OFF			
25	7.9	50			Y
26	8.1	56			Y
27	8.4	40			Y
28	8.5	52			Y
29	OFF	OFF			
30	OFF	OFF			
(NO=N=Excursions) Total N's					0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
Entry Point: EP-D
Sample Period: Jun-22
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Tuesday, July 5, 2022

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381