



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	50			Y
2	8.5	50			Y
3	8.5	48			Y
4	OFF	OFF			
5	OFF	OFF			
6	8.4	38			Y
7	8.4	44			Y
8	8.5	46			Y
9	8.5	46			Y
10	OFF	OFF			
11	OFF	OFF			
12	8.5	42			Y
13	8.5	46			Y
14	8.2	62			Y
15	8.5	58			Y
16	OFF	OFF			
17	OFF	OFF			
18	8.3	50			Y
19	8.5	60			Y
20	8.5	50			Y
21	8.3	56			Y
22	8.6	48			Y
23	OFF	OFF			
24	8.4	50			Y
25	8.4	50			Y
26	8.4	56			Y
27	8.7	56			Y
28	8.5	64			Y
29	8.4	44			Y
30	OFF	OFF			
31	OFF	OFF			

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Jul-22						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:		
pH	<input type="text" value="7.5"/>	
Alk	<input type="text" value="30"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Tuesday, August 2, 2022

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381