



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	8.3	54			Y
3	9.0	70			Y
4	8.0	56			Y
5	8.2	56			Y
6	OFF	OFF			Y
7	8.1	54			Y
8	7.8	60			Y
9	7.9	58			Y
10	OFF	OFF			
11	OFF	OFF			
12	8.0	66			Y
13	7.6	66			Y
14	OFF	OFF			
15	OFF	OFF			
16	7.8	60			Y
17	8.0	64			Y
18	7.9	58			Y
19	OFF	OFF			
20	OFF	OFF			
21	8.1	50			Y
22	7.8	52			Y
23	7.8	52			Y
24	OFF	OFF			
25	OFF	OFF			
26	7.5	50			Y
27	7.7	66			Y
28	7.5	64			Y
29	OFF	OFF			
30	OFF	OFF			
(NO=N=Excursions) Total N's					0

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Sep-22						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Monday, October 3, 2022

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381