



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.6	66			Y
2	8.7	64			Y
3	OFF	OFF			
4	OFF	OFF			
5	8.3	64			Y
6	8.4	68			Y
7	8.3	66			Y
8	OFF	OFF			
9	OFF	OFF			
10	OFF	OFF			
11	8.6	60			Y
12	7.8	60			Y
13	7.8	60			Y
14	OFF	OFF			
15	OFF	OFF			
16	7.8	62			Y
17	7.9	63			Y
18	7.8	60			Y
19	OFF	OFF			
20	7.7	63			Y
21	8.2	60			Y
22	8.4	63			Y
23	OFF	OFF			
24	OFF	OFF			Y
25	8.5	60			Y
26	9.3	58			Y
27	9.3	60			Y
28	OFF	OFF			Y
29	OFF	OFF			Y
30	OFF	OFF			Y
31	OFF	OFF			Y

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Oct-22						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: DARREL LOKARD
 Signature: [Signature]
 Date: 12/9/22

(NO=N=Excursions) Total N's