



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1					N
2					N
3	OFF	OFF			
4	OFF	OFF			
5	8.3	64			Y
6	8.4	68			Y
7	8.3	66			Y
8	OFF	OFF			
9	OFF	OFF			
10	OFF	OFF			
11	8.6	60			Y
12	7.8	60			Y
13	7.8	60			Y
14	OFF	OFF			
15	OFF	OFF			
16	7.8	62			Y
17	7.9	63			Y
18	7.8	60			Y
19	OFF	OFF			
20	7.7	63			Y
21	8.2	60			Y
22	8.4	63			Y
23	OFF	OFF			
24	OFF	OFF			Y
25	8.5	60			Y
26	9.3	58			Y
27	9.3	60			Y
28	OFF	OFF			Y
29	OFF	OFF			Y
30	OFF	OFF			Y
31	OFF	OFF			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity  
 Entry Point: EP-D  
 Sample Period: Oct-22  
 Month / Year

Number of excursions\* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 11/9/2022

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381