



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	9.2	58			Y
2	9.3	60			Y
3	9.3	50			Y
4	9.5	60			Y
5	OFF	OFF			Y
6	OFF	OFF			Y
7	9.3	52			Y
8	7.9	46			Y
9	7.9	50			Y
10	OFF	OFF			Y
11	OFF	OFF			Y
12	OFF	OFF			Y
13	7.9	54			Y
14	8.7	56			Y
15	OFF	OFF			Y
16	OFF	OFF			Y
17	8.1	46			Y
18	8.5	52			Y
19	8.7	51			Y
20	8.6	52			Y
21	8.7	48			Y
22	9.0	54			Y
23	8.2	50			Y
24	OFF	OFF			Y
25	OFF	OFF			Y
26	OFF	OFF			Y
27	8.6	52			Y
28	8.7	50			Y
29	8.7	50			Y
30	OFF	OFF			Y
31					N

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Nov-22						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Darrel Lockard
Signature: *Darrel Lockard*

Date: 12/10/2022

(NO=N=Excursions) **Total N's**