



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	6.9	50			N
2	7.0	35			N
3	OFF	OFF			
4	OFF	OFF			
5	OFF	OFF			
6	7.5	40			Y
7	7.6	46			Y
8	OFF	OFF			
9	OFF	OFF			
10	OFF	OFF			
11	7.5	50			Y
12	7.5	40			Y
13	OFF	OFF			
14	7.7	46			Y
15	7.5	44			Y
16	7.6	46			Y
17	7.6	45			Y
18	OFF	OFF			
19	OFF	OFF			
20	OFF	OFF			
21	7.6	52			Y
22	7.7	52			Y
23	7.7	52			Y
24	OFF	OFF			
25	OFF	OFF			
26	OFF	OFF			
27	7.5	50			y
28	OFF	OFF			
29	7.5	45			y
30	7.5	44			y
31	7.5	50			y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Dec-22
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 1/10/2023

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381