



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	9.4	80			Y
2	9.4	70			Y
3	OFF	OFF			Y
4	OFF	OFF			Y
5	OFF	OFF			Y
6	8.7	58			Y
7	9.1	60			Y
8	7.7	44			Y
9	7.7	50			Y
10	8.1	50			Y
11	OFF	OFF			
12	OFF	OFF			
13	8.2	52			Y
14	7.6	45			Y
15	7.7	45			Y
16	7.7	50			Y
17	OFF	OFF			Y
18	OFF	OFF			Y
19	OFF	OFF			Y
20	7.7	50			Y
21	8.0	50			Y
22	7.9	50			Y
23	8.0	35			Y
24	OFF	OFF			
25	OFF	OFF			
26	OFF	OFF			
27	OFF	OFF			
28	8.1	55			Y
29	7.5	66			Y
30	8.4	59			Y
31	8.5	58			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Mar-23
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

7.5

 Alk

30

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Sili

--

 (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 4/7/23

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381