



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			Y
2	OFF	OFF			Y
3	8.3	66			Y
4	8.9	58			Y
5	8.7	60			Y
6	7.7	50			Y
7	OFF	OFF			
8	OFF	OFF			
9	OFF	OFF			
10	8.0	60			Y
11	8.7	65			Y
12	8.2	56			Y
13	7.8	56			Y
14	7.7	58			Y
15	OFF	OFF			
16	OFF	OFF			
17	8.2	55			Y
18	7.8	42			Y
19	8.3	55			Y
20	8.5	57			Y
21	OFF	OFF			
22	OFF	OFF			
23	7.8	50			Y
24	7.8	42			Y
25	8.0	50			Y
26	7.8	55			Y
27	7.8	55			Y
28	7.8	56			Y
29	OFF	OFF			Y
30	OFF	OFF			Y
31					N

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Apr-23
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 5/8/2023

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381