



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1 | 7.9 | 60 | | | Y |
| 2 | 7.6 | 50 | | | Y |
| 3 | 7.5 | 55 | | | Y |
| 4 | 7.9 | 60 | | | Y |
| 5 | 7.7 | 60 | | | Y |
| 6 | OFF | OFF | | | |
| 7 | OFF | OFF | | | |
| 8 | 7.7 | 60 | | | Y |
| 9 | 7.6 | 65 | | | Y |
| 10 | 7.7 | 62 | | | Y |
| 11 | 7.5 | 55 | | | Y |
| 12 | 7.6 | 56 | | | Y |
| 13 | 7.7 | 38 | | | Y |
| 14 | 7.8 | 38 | | | Y |
| 15 | 7.8 | 55 | | | Y |
| 16 | 8.8 | 45 | | | Y |
| 17 | 8.6 | 42 | | | Y |
| 18 | 9.3 | 60 | | | Y |
| 19 | 9.6 | 75 | | | Y |
| 20 | OFF | OFF | | | Y |
| 21 | 7.8 | 50 | | | Y |
| 22 | 8.3 | 48 | | | Y |
| 23 | 8.8 | 50 | | | Y |
| 24 | 8.7 | 44 | | | Y |
| 25 | 8.4 | 40 | | | Y |
| 26 | 8.8 | 50 | | | Y |
| 27 | 7.8 | 40 | | | Y |
| 28 | 7.8 | 43 | | | Y |
| 29 | 8.1 | 40 | | | Y |
| 30 | 8.1 | 50 | | | Y |
| 31 | 7.7 | 45 | | | Y |

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

| | | | | | | |
|---|---|---|---|---|---|---|
| 4 | 1 | 0 | 0 | 0 | 4 | 1 |
|---|---|---|---|---|---|---|

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: May-23
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

| | | |
|------|-----|------------------|
| pH | 7.5 | |
| Alk | 30 | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Sili | | (Silicate) |

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 6/10/23

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381