



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.3	50			Y
2	8.3	52			Y
3	8.4	52			Y
4	8.4	52			Y
5	8.5	48			Y
6	7.9	46			Y
7	7.9	48			Y
8	7.8	47			Y
9	7.7	55			Y
10	8.1	51			Y
11	8.3	53			Y
12	7.7	43			Y
13	7.6	50			Y
14	7.5	45			Y
15	8.8	55			Y
16	7.9	50			Y
17	8.1	45			Y
18	8.1	50			Y
19	8.6	52			Y
20	8.6	54			Y
21	8.3	47			Y
22	OFF	OFF			
23	OFF				
24	8.3	52			Y
25	8.3	52			Y
26	7.7	48			Y
27	7.8	50			Y
28	7.6	50			Y
29	7.9	58			Y
30	8.1	45			Y
31					N

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Jun-23						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 7/10/2023

(NO=N=Excursions) **Total N's**