



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	48			Y
2	8.1	54			Y
3	7.5	51			Y
4	OFF	OFF			
5	7.5	53			Y
6	7.5	55			Y
7	7.5	50			Y
8	8.8	55			Y
9	8.4	60			Y
10	7.7	55			Y
11	7.8	57			Y
12	7.8	58			Y
13	7.5	52			Y
14	8.1	66			Y
15	8.1	60			Y
16	OFF	OFF			
17	7.9	62			Y
18	9.0	62			Y
19	8.9	58			Y
20	9.2	65			Y
21	8.9	55			Y
22	8.7	50			Y
23	8.9	54			Y
24	7.8	52			Y
25	7.8	55			Y
26	7.8	53			Y
27	7.9	55			Y
28	8.6	48			Y
29	8.4	50			Y
30	8.3	48			Y
31	9.3	74			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
Entry Point: EP-D
Sample Period: Jul-23
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: DARREL LOCKARD

Signature: *Darrel Lockard*

Date: 8/10/2023

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381