



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	48			Y
2	7.7	58			Y
3	OFF	OFF			
4	7.2	58			Y
5	7.5	46			Y
6	7.8	48			Y
7	8.6	55			Y
8	8.3	55			Y
9	8.2	45			Y
10	OFF	OFF			
11	8.0	50			Y
12	8.3	53			Y
13	8.7	57			Y
14	8.9	60			Y
15	8.9	62			Y
16	OFF	OFF			
17	OFF	OFF			
18	8.3	53			Y
19	8.2	56			Y
20	7.9	52			Y
21	OFF	OFF			
22	7.8	45			Y
23	7.6	48			Y
24	8.5	60			Y
25	OFF	OFF			
26	8.5	54			Y
27	8.6	55			Y
28	8.8	50			Y
29	8.6	50			Y
30	OFF	OFF			
31					

<< Have minimums been met for this day?

ENTRY POINT	
PWS ID:	4 1 0 0 0 4 1
System Name:	City of Amity
Entry Point:	EP-D
Sample Period:	oct. 2023
	Month / Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 11/10/2023

(NO=N=Excursions) **Total N's**