



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.5	35			Y
2	8.4	35			Y
3	8.3	37			Y
4	8.3	38			Y
5	8.3	38			Y
6	7.7	45			Y
7	7.5	40			Y
8	7.7	50			Y
9	7.6	50			Y
10	OFF	OFF			
11	OFF	OFF			
12	7.9	52			Y
13	8.0	51			Y
14	8.5	40			Y
15	7.8	42			Y
16	OFF	OFF			
17	OFF	OFF			
18	OFF	OFF			
19	8.0	45			Y
20	8.0	47			Y
21	8.9	48			Y
22	8.7	47			Y
23	OFF	OFF			Y
24	OFF	OFF			Y
25	8.5	50			Y
26	7.6	43			Y
27	7.7	48			Y
28	7.7	47			Y
29	7.8	52			Y
30	7.8	50			Y
31					N

<< Have minimums been met for this day?

<b>ENTRY POINT</b>							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	NOV. 23						
	Month / Year						

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>		
pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 12/10/2023

(NO=N=Excursions) **Total N's**