



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	51			Y
2	7.8	50			Y
3	off				off
4	7.6	54			Y
5	7.5	51			Y
6	7.4	50			Y
7	7.6	45			Y
8	7.5	42			Y
9	7.5	44			Y
10	OFF	OFF			
11	7.7	59			Y
12	7.5	58			Y
13	7.6	58			Y
14	7.5	48			Y
15	off				off
16	off				off
17	7.5	55			Y
18	7.7	56			Y
19	7.9	59			Y
20	7.8	61			Y
21	7.6	54			Y
22	7.6	57			Y
23	7.5	52			Y
24	7.5	52			Y
25	7.6	55			Y
26	8.1	74			Y
27	8.0	69			Y
28	8.2	70			Y
29	7.0	43			N
30	7.3	34			N
31	6.8	32			N

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: DEC.23
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: _____

Date: 1/9/2024

(NO=N=Excursions) Total N's

3

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381