



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			Y
2	8.6	58			Y
3	8.0	62			Y
4	8.9	55			Y
5	8.2	56			Y
6	OFF	OFF			Y
7	OFF	OFF			Y
8	8.1	66			Y
9	8.0	54			Y
10	7.7	57			Y
11	7.6	53			Y
12	OFF	OFF			Y
13	OFF	OFF			Y
14	7.6	60			Y
15	7.5	49			Y
16	7.8	53			Y
17	7.5	59			Y
18	7.5	52			Y
19	7.5	48			Y
20	7.6	48			Y
21	7.6	50			Y
22	7.6	52			Y
23	7.5	58			Y
24	7.7	64			Y
25	7.6	59			Y
26	7.7	59			Y
27	OFF	OFF			
28	7.6	48			Y
29	7.9	57			Y
30	7.6	58			Y
31	7.5	67			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity  
**Entry Point:** EP-D  
**Sample Period:** Jan-24  
 Month / Year

**Number of excursions\* during this month:**

(Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 

7.5
-----

  
 Alk 

30
----

 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Sili 

--

 (Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 2/9/2024

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381