



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	61			Y
2	7.6	60			Y
3	7.9	62			Y
4	OFF	OFF			
5	8.5	69			Y
6	7.9	55			Y
7	8.1	60			Y
8	8.6	72			Y
9	7.9	55			Y
10	7.8	53			Y
11	7.7	60			Y
12	7.9	75			Y
13	8.0	71			Y
14	7.8	68			Y
15	7.7	65			Y
16	7.5	50			Y
17	7.8	55			Y
18	7.6	50			Y
19	7.7	55			Y
20	7.9	64			Y
21	OFF	OFF			
22	8.7	67			Y
23	8.4	63			Y
24	8.0	68			Y
25	8.0	67			Y
26	7.6	54			Y
27	OFF	OFF			
28	7.6	50			Y
29	7.7	52			Y
30					
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Feb-24
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 3/10/2024

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381