



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	50			Y
2	7.5	52			Y
3	OFF	OFF			off
4	8.0	57			Y
5	7.5	49			Y
6	7.8	57			Y
7	7.6	53			Y
8	8.0	62			Y
9	7.7	54			Y
10	7.8	55			Y
11	8.0	66			Y
12	OFF	OFF			off
13	7.7	45			Y
14	7.8	55			Y
15	8.0	63			Y
16	7.5	55			Y
17	OFF	OFF			off
18	7.7	60			Y
19	7.7	58			Y
20	OFF	OFF			off
21	OFF	OFF			off
22	7.7	51			Y
23	7.8	63			Y
24	8.4	60			Y
25	8.7	63			Y
26	7.9	60			Y
27	8.0	58			Y
28	8.9	72			Y
29	8.1	64			Y
30	7.5	50			Y
31	7.5	52			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
Entry Point: EP-D
Sample Period: Mar-24
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

7.5

 Alk

30

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Sili

--

 (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 4/8/2024

(NO=N=Excursions) **Total N's**

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381