



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.4	7.6			Y
2	OFF	OFF			Y
3	8.6	75			Y
4	8.7	75			Y
5	9.5	98			Y
6	9.3	62			Y
7	9.4	64			Y
8	9.0	55			Y
9	9.2	65			Y
10	9.0	54			Y
11	8.8	55			Y
12	9.0	56			Y
13	8.8	52			Y
14	8.5	50			Y
15	9.0	61			Y
16	9.3	62			Y
17	9.1	56			Y
18	9.1	50			Y
19	9.1	58			Y
20	8.8	45			Y
21	8.7	40			Y
22	9.0	51			Y
23	8.7	53			Y
24	8.5	51			Y
25	8.6	50			Y
26	8.6	49			Y
27	8.5	42			Y
28	8.5	42			Y
29	8.5	49			Y
30	8.8	44			Y
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity

Entry Point: EP-D

Sample Period: Apr-24
Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature:

Date: 5/7/24

(NO=N=Excursions) Total N's