



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.9	35			Y
2	8.6	33			y
3	8.7	32			Y
4	OFF	OFF			y
5	OFF	OFF			y
6	9.0	49			Y
7	9.0	45			Y
8	8.9	45			Y
9	8.8	41			Y
10	8.7	40			Y
11	7.7	30			Y
12	8.2	31			y
13	OFF	OFF			y
14	8.4	42			Y
15	8.0	30			Y
16	7.9	36			Y
17	8.0	35			Y
18	off	off			Y
19	7.8	33			Y
20	7.9	40			Y
21	8.5	49			Y
22	8.6	51			Y
23	OFF	OFF			Y
24	OFF	OFF			Y
25	9.0	60			Y
26	8.0	52			Y
27	8.7	57			Y
28	8.7	58			Y
29	8.6	62			Y
30	off	off			Y
31	7.8	40			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity

Entry Point: EP-D

Sample Period: May-24  
Month / Year

Number of excursions\* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH	<input type="text" value="7.5"/>	
Alk	<input type="text" value="30"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Darrel Lockard Cert #2853

Signature: *Darrel Lockard*

Date: 6/10/2024

(NO=N=Excursions) Total N's