



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.0	40			Y
2	7.9	40			Y
3	8.1	42			Y
4	8.8	48			Y
5	8.3	35			Y
6	8.5	47			Y
7	8.6	54			Y
8	8.2	50			Y
9	8.1	52			Y
10	8.7	50			Y
11	OFF	OFF			off
12	8.6	51			Y
13	8.7	52			Y
14	7.8	40			Y
15	7.9	32			Y
16	7.5	33			Y
17	8.5	33			Y
18	7.9	33			Y
19	8.0	31			Y
20	7.6	32			Y
21	7.9	38			Y
22	7.6	32			Y
23	OFF	OFF			off
24	7.5	34			Y
25	7.5	45			Y
26	7.8	67			Y
27	7.5	50			Y
28	9.0	58			Y
29	8.9	65			Y
30	8.8	60			Y
31					

<< Have minimums
been met for this
day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity

Entry Point: EP-D

Sample Period: Jun-24

Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<table border="1"><tr><td>7.5</td></tr></table>	7.5	
7.5			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	(Alkalinity)
30			
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Sili	<table border="1"><tr><td></td></tr></table>		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 7/10/2024

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381