



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.8	58			Y
2	8.2	50			Y
3	8.2	45			Y
4	8.1	45			Y
5	8.2	48			Y
6	8.2	48			Y
7	7.9	48			Y
8	8.2	53			Y
9	8.7	60			Y
10	8.8	62			Y
11	8.2	59			Y
12	8.8	62			Y
13	9.0	65			Y
14	9.0	66			Y
15	8.6	50			Y
16	8.9	50			Y
17	8.8	50			Y
18	8.6	52			Y
19	9.0	62			Y
20	8.8	58			Y
21	9.0	58			Y
22	8.8	57			Y
23	8.7	54			Y
24	OFF	OFF			
25	8.6	45			Y
26	9.0	62			Y
27	8.7	53			Y
28	8.8	55			Y
29	8.6	52			Y
30	9.0	64			Y
31	8.3	61			Y

<< Have minimums
been met for this
day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity

Entry Point: EP-D

Sample Period: AUG. 24

Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<table border="1"><tr><td>7.5</td></tr></table>	7.5	
7.5			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	(Alkalinity)
30			
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Sili	<table border="1"><tr><td></td></tr></table>		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 9/4/2024

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381