



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.2	55			Y
2	8.7	53			Y
3	8.6	55			Y
4	8.3	59			Y
5	8.3	58			Y
6	8.6	57			Y
7	8.7	50			Y
8	8.7	52			Y
9	8.7	55			Y
10	8.3	50			Y
11	8.3	48			Y
12	8.5	50			Y
13	off	off			off
14	8.5	45			Y
15	8.7	52			Y
16	8.9	63			Y
17	8.6	59			Y
18	8.6	55			Y
19	9.1	60			Y
20	8.8	60			Y
21	9.0	14.6			Y
22	8.9	14.8			Y
23	9.0	15.1			Y
24	8.9	59			Y
25	8.6	54			Y
26	8.6	60			Y
27	8.7	51			Y
28	8.6	52			Y
29	8.3	52			Y
30	8.2	59			Y
31					N

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: **4 1 0 0 0 4 1**

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Sept. 24
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH **7.5**
 Alk **30** (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 10/10/2024

(NO=N=Excursions) Total N's **0**

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381