



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	54			Y
2	7.5	54			Y
3	7.8	65			Y
4	7.7	59			Y
5	7.8	57			Y
6	9.7	45			Y
7	8.7	35			Y
8	7.7	40			Y
9	8.8	38			Y
10	7.6	32			Y
11	7.6	33			Y
12	7.5	40			Y
13	8.2	40			Y
14	7.5	52			Y
15	7.5	51			Y
16	OFF				off
17	7.5	48			Y
18	7.6	46			Y
19	7.6	51			Y
20	7.7	53			Y
21	7.6	54			Y
22	8.4	58			Y
23	OFF	OFF			OFF
24	8.1	61			Y
25	7.6	50			Y
26	7.6	51			Y
27	7.5	59			Y
28	8.8	50			Y
29	OFF	OFF			OFF
30	7.6	45			Y
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: **4 1 0 0 0 4 1**

System Name: City of Amity
Entry Point: EP-D
Sample Period: Nov.24
Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH **7.5**
 Alk **30** (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 12/10/2024

(NO=N=Excursions) **Total N's** **0**

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381