



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.0	52			Y
2	7.6	52			Y
3	9.7	43			Y
4	9.7	40			Y
5	9.7	40			Y
6	8.1	42			Y
7	9.1	42			Y
8	9.0	40			Y
9	9.2	54			Y
10	9.3	40			Y
11	9.1	44			Y
12	8.0	57			Y
13	7.7	58			Y
14	Off	OFF			OFF
15	7.6	56			Y
16	9.4	40			Y
17	7.6	59			Y
18	7.5	52			Y
19	7.5	61			Y
20	7.5	53			Y
21	7.5	51			Y
22	7.5	53			Y
23	OFF	OFF			OFF
24	8.2	64			Y
25	8.0	60			Y
26	7.9	57			Y
27	7.6	55			Y
28	7.6	50			Y
29	7.6	50			Y
30	off	off			off
31	7.7	50			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity

Entry Point: EP-D

Sample Period: DEC. 24

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<u>7.5</u>	
Alk	<u>30</u>	(Alkalinity)
PO4	<u> </u>	(Orthophosphate)
Sili	<u> </u>	(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 1/10/2025

(NO=N=Excursions) Total N's 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381