



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	60			Y
2	7.9	55			Y
3	8.0	57			Y
4	7.8	59			Y
5	8.1	64			Y
6	OFF	OFF			
7	7.8	56			Y
8	7.6	50			Y
9	8.1	53			Y
10	8.9	58			Y
11	8.7	57			Y
12	8.2	58			Y
13	7.7	63			Y
14	7.7	50			Y
15	7.8	50			Y
16	7.7	54			Y
17	8.3	55			Y
18	7.9	52			Y
19	8.0	63			Y
20	7.9	60			Y
21	8.4	70			Y
22	7.6	65			Y
23	7.6	68			Y
24	7.7	66			Y
25	OFF	OFF			Y
26	7.6	48			Y
27	9.2	47			Y
28	7.9	57			Y
29	7.6	59			Y
30	8.5	48			Y
31	8.6	45			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Jan. 25
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 2/10/2025

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381