



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.8	43			Y
2	7.5	52			Y
3	7.5	48			Y
4	7.5	50			Y
5	8.1	35			Y
6	8.6	35			Y
7	8.9	39			Y
8	off	off			off
9	off	off			off
10	8.1	40			Y
11	8.9	43			Y
12	9.1	44			Y
13	9.4	48			Y
14	9.5	63			Y
15	9.4	47			Y
16	9.4	49			Y
17	9.4	52			Y
18	9.6	40			Y
19	9.1	40			Y
20	9.1	47			Y
21	8.0	50			Y
22	8.6	56			Y
23	7.5	54			Y
24	7.5	55			Y
25	off	off			Y
26	off	off			off
27	off	off			off
28	7.5	55			Y
29					
30					
31					

(NO=N=Excursions) Total N's 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 4 1 0 0 0 4 1

System Name: City of Amity

Entry Point: EP-D

Sample Period: Feb. 25
Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4	 	(Orthophosphate)
Sili	 	(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 3/10/2025