



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	50			Y
2	7.5	50			Y
3	7.5	60			Y
4	8.2	60			Y
5	8.0	65			Y
6	7.8	60			Y
7	7.8	62			Y
8	7.7	70			Y
9	7.6	72			Y
10	7.5	54			Y
11	9.8	60			Y
12	9.3	50			Y
13	9.2	52			Y
14	9.1	45			Y
15	7.5	60			Y
16	7.5	55			Y
17	7.8	58			Y
18	7.5	62			Y
19	7.6	65			Y
20	7.5	62			Y
21	7.6	64			Y
22	7.5	62			Y
23	7.5	62			Y
24	7.6	53			Y
25	7.5	52			Y
26	7.5	54			Y
27	7.8	59			Y
28	7.5	66			Y
29	7.5	65			Y
30	7.5	60			Y
31	7.5	54			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Mar-25
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<table border="1"><tr><td>7.5</td></tr></table>	7.5	
7.5			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	(Alkalinity)
30			
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Sili	<table border="1"><tr><td></td></tr></table>		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: Apr 8 2025

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381