



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	55			Y
2	7.6	60			Y
3	9.5	47			Y
4	9.3	40			Y
5	9.1	40			Y
6	off	off			
7	9.4	50			Y
8	9.3	52			Y
9	7.9	52			Y
10	7.5	53			Y
11	7.5	53			Y
12	8.7	40			Y
13	9.2	45			Y
14	9.1	40			Y
15	off	off			
16	9.0	40			Y
17	9.0	40			Y
18	9.1	42			Y
19	off				
20	8.5	44			Y
21	8.4	40			Y
22	8.2	43			Y
23	9.2	50			Y
24	9.0	45			Y
25	9.0	45			Y
26	off	off			
27	off	off			
28	9.0	50			Y
29	9.1	50			Y
30	8.2	41			Y
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Apr-25
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 5/8/2025

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381