



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.9	40			Y
2	9.1	45			Y
3	9.0	45			Y
4	off	off			off
5	8.8	42			Y
6	8.5	42			Y
7	8.7	45			Y
8	8.9	52			Y
9	9.0	55			Y
10	8.4	52			Y
11	8.6	54			Y
12	8.4	43			Y
13	8.8	52			Y
14	8.8	42			Y
15	8.4	40			Y
16	8.5	40			Y
17	8.5	41			Y
18	8.6	40			Y
19	7.7	42			Y
20	7.8	44			Y
21	8.0	44			Y
22	off	off			off
23	8.1	45			Y
24	7.5	52			Y
25	7.5	55			Y
26	7.5	55			Y
27	7.5	37			Y
28	7.6	38			Y
29	7.5	37			Y
30	9.4	74			Y
31	9.3	66			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 4 1 0 0 0 4 1

System Name: City of Amity
Entry Point: EP-D
Sample Period May-25
Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 6/9/2025

(NO=N=Excursions) **Total N's** 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381