



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	9.2	58			Y
2	9.1	62			Y
3	9.0	53			Y
4	8.9	50			Y
5	8.5	46			Y
6	8.5	45			Y
7	7.9	42			Y
8	7.9	44			Y
9	7.8	40			Y
10	8.4	48			Y
11	7.9	46			Y
12	8.1	43			Y
13	8.1	40			Y
14	8.0	40			Y
15	7.8	40			Y
16	8.2	43			Y
17	8.2	42			Y
18	8.1	43			Y
19	8.1	51			Y
20	8.6	57			Y
21	off	off			off
22	8.0	50			Y
23	8.3	45			Y
24	8.2	41			Y
25	8.0	40			Y
26	7.8	40			Y
27	8.3	43			Y
28	8.0	41			Y
29	8.1	44			Y
30	8.1	43			Y
31					

<< Have minimums
been met for this
day?

ENTRY POINT

PWS ID: **4 1 0 0 0 4 1**

System Name: City of Amity

Entry Point: EP-D

Sample Period: Jun-25
Month / Year

Number of excursions* during this month:
(Count the number of days when any WQP was less than the
minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH **7.5**
Alk **30** (Alkalinity)
PO4 (Orthophosphate)
Sili (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 7/10/2025

(NO=N=Excursions) Total N's **0**

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381