



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	50			Y
2	7.7	43			Y
3	7.7	43			Y
4	off	off			
5	7.9	42			Y
6	7.7	40			Y
7	7.8	40			Y
8	8.0	40			Y
9	8.0	45			Y
10	7.6	59			Y
11	off	off			Y
12	8.1	54			Y
13	7.8	54			Y
14	7.7	41			Y
15	8.0	47			Y
16	8.0	44			Y
17	8.7	53			Y
18	9.1	57			Y
19	8.5	54			Y
20	8.3	45			Y
21	9.0	55			Y
22	8.4	48			Y
23	8.3	46			Y
24	8.4	54			Y
25	8.5	52			Y
26	8.2	51			Y
27	7.9	52			Y
28	8.1	45			Y
29	8.0	40			Y
30	8.0	52			Y
31	8.1	44			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: July
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<table border="1"><tr><td>7.5</td></tr></table>	7.5	
7.5			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	(Alkalinity)
30			
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Sili	<table border="1"><tr><td></td></tr></table>		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 8/10/2025

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381