



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.4	52			Y
2	8.3	46			Y
3	8.2	50			Y
4	7.9	50			Y
5	7.8	46			Y
6	7.9	45			Y
7	7.9	50			Y
8	off	off			
9	8.0	56			Y
10	7.9	54			Y
11	8.2	57			Y
12	7.9	58			Y
13	7.9	53			Y
14	7.9	45			Y
15	8.1	46			Y
16	off	off			
17	8.2	48			Y
18	7.9	50			Y
19	7.9	45			Y
20	7.9	45			Y
21	8.0	57			Y
22	8.1	48			Y
23	off	off			
24	7.8	58			Y
25	8.0	56			Y
26	8.1	45			Y
27	8.2	50			Y
28	8.2	51			Y
29	8.0	50			Y
30	8.1	50			Y
31	off	off			

(NO=N=Excursions) Total N's 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 4 1 0 0 0 4 1

System Name: City of Amity

Entry Point: EP-D

Sample Period: AUG.25
Month / Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4	 	(Orthophosphate)
Sili	 	(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 9/10/2025