



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	50			Y
2	8.0	47			Y
3	7.9	47			Y
4	7.6	50			Y
5	7.9	54			Y
6	8.1	52			Y
7	7.8	51			Y
8	8.5	56			Y
9	8.3	52			Y
10	off	off			
11	7.8	40			Y
12	8.1	50			Y
13	8.2	52			Y
14	8.2	46			Y
15	8.2	50			Y
16	8.1	50			Y
17	off	off			
18	8.5	52			Y
19	8.5	60			Y
20	8.7	59			Y
21	8.5	56			Y
22	8.6	60			Y
23	8.7				Y
24	8.2	50			Y
25	8.3	48			Y
26	8.1	52			Y
27	8.5	50			Y
28	8.5	50			Y
29	8.5	48			Y
30	off	off			off
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 4 1 0 0 0 4 1

System Name: City of Amity
Entry Point: EP-D
Sample Period: Sept. 25
Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 10/10/2025

(NO=N=Excursions) **Total N's** 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381