



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.1	71			Y
2	off	off			Y
3	7.9	60			Y
4	7.6	50			Y
5	7.4	58			N
6	7.6	50			Y
7	8.1	58			Y
8	8.3	67			Y
9	8.9	70			Y
10	9.1	68			Y
11	8.1	60			Y
12	7.5	40			Y
13	8.8	82			Y
14	7.1	50			N
15	7.1	35			N
16	7.2	35			N
17	7.5	48			Y
18	8.1	60			Y
19	9.0	69			Y
20	8.7	73			Y
21	8.5	63			Y
22	7.1	49			N
23	7.2	48			N
24	7.1	35			N
25	7.1	45			N
26	7.1	38			N
27	7.4	44			N
28	7.5	35			Y
29	8.3	56			Y
30	8.8	65			Y
31					
(NO=N=Excursions) Total N's					10

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Nov. 25						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only		
Minimum Water Quality Parameters as set by State:		
pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 12/3/2025