



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.9	80			Y
2	7.9	35			Y
3	8.5	67			Y
4	8.5	66			Y
5	8.8	83			Y
6	7.7	40			Y
7	7.6	45			Y
8	7.6	50			Y
9	7.6	60			Y
10	7.6	52			Y
11	7.6	58			Y
12	off	off			off
13	off	off			off
14	off	off			off
15	7.6	48			Y
16	7.9	60			Y
17	8.3	60			Y
18	8.1	72			Y
19	7.7	55			Y
20	7.6	52			Y
21	7.5	57			Y
22	8.3	63			Y
23	7.9	65			Y
24	8.4	65			Y
25	8.3	64			Y
26	7.8	66			Y
27	8.2	72			Y
28	8.9	85			Y
29	8.4	72			Y
30	7.9	73			Y
31	7.5	55			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Dec. 25
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 1/9/2026

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381