



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	62			Y
2	7.8	78			Y
3	8.5	80			Y
4	7.9	77			Y
5	7.5	42			Y
6	7.5	55			Y
7	7.7	53			Y
8	7.9	65			Y
9	7.7	62			Y
10	8.4	75			Y
11	8.4	75			Y
12	7.5	60			Y
13	8.0	52			Y
14	9.5	100			Y
15	9.2	97			Y
16	9.0	93			Y
17	8.2	72			Y
18	8.9	80			Y
19	9.4	50			Y
20	9.4	46			Y
21	8.9	51			Y
22	9.0	50			Y
23	9.0	52			Y
24	8.9	47			Y
25	9.0	42			Y
26	8.4	40			Y
27	8.6	40			Y
28	off	off			Y
29	off	off			Y
30	off	off			Y
31	8.9	40			Y

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Jan. 26						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 2/10/2026

(NO=N=Excursions) **Total N's**