



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	9.1	45			Y
2	9.2	40			Y
3	9.1	44			Y
4	9.0	40			Y
5	9.1	46			Y
6	9.1	44			Y
7	8.0	46			Y
8	8.6	35			Y
9	8.4	35			Y
10	7.6	55			Y
11	7.6	79			Y
12	8.7	50			Y
13	9.1	45			Y
14	8.4	44			Y
15	7.7	37			Y
16	8.3	42			Y
17	off	off			off
18	off	off			off
19	off	off			off
20	8.9	40			Y
21	8.6	40			Y
22	8.0	45			Y
23	8.9	40			Y
24	7.5	35			Y
25	7.9	40			Y
26	8.7	37			Y
27	8.4	42			Y
28	8.3	41			Y
29					
30					
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Feb. 26
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

7.5

 Alk

30

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Sili

--

 (Silicate)

Print Name: Darrel Lockard

Signature: _____

Date: 3/10/2026

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381